


NOTE 1

NOTE-1 Slot, mounting holes and shelf holes are the same as the "J" Panel Cage 1 shown on Drawing 6-5-8

NOTE-2 #8 Equipment Ground wire shall be terminated here



NOTE 3 Protective device slips under two screw terminals and the Equipment Ground pig-tail is attached to the Equipment Ground bus bar.

NOTE-4 10, 12 Position Terminal Blocks are equivalent to Marathon PN 672R212. #8-32 Screw spaced at 9/16"

NOTE-5 Four 10 position Equipment Ground copper bus bars

NOTE 4

NOTE 5

NOTE 2

TITLE:		INPUT TERMINATION PANEL HOUSING 1
Rev Date 09-05-03		6-5-13
MAY 8, 2003		